


Permit Reference Number : EPR / TP3836CT

Operator : Viridor

Installation: Beddington

Form Number: AIR 2 / 23/07/13 [A1]

Reporting of Continuously Monitored Emissions to Air for VOC mg/m3 at Emission Point A1 For the month of June 2024



Monthly summary		Date	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
Half-hourly average		Half-hourly average ELV	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0	20.0
	Monthly maximum	48.9	Maximum Half-hourly average	1.5	1.5	2.6	0.5	1.7	1.1	0.8	4.0	3.1	1.3	3.7	0.9	1.2	3.6	4.4	14.3	22.2	0.6	0.6	2.0	2.0	0.6	2.6	48.9	0.8	2.6	0.6	0.6	1.9	0.6
	Monthly mean	0.6	Mean Half-hourly average	0.5	0.5	0.5	0.4	0.7	0.5	0.5	0.6	0.6	0.5	0.6	0.5	0.5	0.6	0.5	1.2	0.6	0.2	0.5	0.5	0.0	0.4	0.6	2.0	0.5	0.5	0.5	0.5	0.5	
	Monthly minimum	0.0	Minimum Half-hourly average	0.4	0.4	0.3	0.0	0.5	0.4	0.4	0.4	0.5	0.4	0.5	0.5	0.0	0.4	0.0	0.4	0.0	0.0	0.5	0.4	0.0	0.2	0.4	0.4	0.4	0.4	0.1	0.4	0.4	0.4
	Total Invalid results	0	No of Invalid results	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Sum of exceedances	2	No of exceedances of ELV	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	0	0	0	0	0	0
Daily average		Daily average ELV	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
	Monthly maximum	2.0	Daily average	0.5	0.5	0.5	0.4	0.7	0.5	0.5	0.6	0.6	0.5	0.6	0.5	0.5	0.6	0.5	N/A	0.6	0.2	0.5	0.5	0.0	N/A	0.6	2.0	N/A	0.5	0.5	0.5	0.5	0.5
	No of invalid days	0	Value Valid?	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y	Y
	Sum of exceedances	0	Value Exceeds ELV?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

Signed D. Indesic

Date 1.07.2024

(Authorised to sign as a representative of the Operator)